



NOTES

1. WHERE SOIL CONDITIONS CANNOT BE MAINTAINED AS SHOWN ABOVE, PROVIDE APPROVED METHOD OF CONSTRUCTION.
2. SHEETING WILL BE REQUIRED AS DETERMINED IN THE FIELD.
3. COMPACTION PERCENTAGES SHOWN REFER TO AASHTO T-180.
4. MECHANICAL COMPACTION NOT ALLOWED BELOW THIS LEVEL OTHER THAN HAND VIBRATORY MEANS.
5. TRENCH WIDTH "W" = PIPE O.D. PLUS 2'-0".
6. 2" WIDE DETECTION TAPE WITH METALLIC BACKING TO BE INSTALLED OVER MAIN 1' BELOW SURFACE. TAPE TO BE MARKED-"CAUTION: WATER LINE BELOW", CAUTION: FORCE MAIN BELOW", OR "CAUTION: REUSE WATER MAIN BELOW". TRACE WIRE SHALL ALSO BE USED CONTINUOUSLY ON ALL PIPE. (SEE DETAIL M-14).
7. ALL RESTORATION IN EASEMENTS OR RIGHTS OF WAY OR WHEN REQUIRED BY OTHER JURISDICTIONAL AGENCIES SHALL CONFORM TO IRCDUS SPECIFICATIONS OR THE OTHER JURISDICTIONAL AGENCY SPECIFICATIONS, WHICHEVER IS MORE STRINGENT.
8. ALL PIPE TO BE LOCATED 5' O.C. (TYPICAL) FROM EDGE OF PAVEMENT, PER FDOT INDEX 105.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITIES SERVICES



TRENCH DETAIL
(UNPAVED EASEMENTS)

DRAWING
NO.

M-1

SEPTEMBER 2011