



ELEVATION

NOTES

1. ALL VALVE BOLTS SHALL BE STAINLESS STEEL WITH BRASS NUTS
2. PERMANENT LAND MARKERS ARE TO BE USED OVER ALL F.M. VALVES (SEE M-11)
3. ALL VALVES REQUIRE A LAT & LONG IN DEGREES & MINUTES
4. SEE TRACER WIRE DETAIL. M-14
5. RPMS ARE TO BE LOCATED IN ROADWAY FOR ALL WATER VALVES. (SEE W-1)
6. REFLECTIVE MARKERS FOR:
  - FIRE HYDRANT (WATER) - BLUE
  - WATER MAIN VALVE - WHITE
  - FORCE MAIN VALVE - GREEN
  - REUESE MAIN VALVE - PURPLE
  - BRINE - ORANGE
7. VALVE BOX LID SHALL BE A MINIMUM 24 LBS. WITH A MINIMUM 6" (LONG THROAT) LID.
8. VALVE BOX SHALL COMPLY WITH FDOT STANDARDS IF APPLICABLE.

INDIAN RIVER COUNTY  
DEPARTMENT OF  
UTILITIES SERVICES



VALVE AND BOX

DRAWING  
NO.

M-5