



## NOTES

1. VALVE BOX LID SHALL BE PAINTED:
  - BLUE - WATER
  - GREEN - FORCE MAINS
  - PURPLE - REUSE WATER
  - BRINE - ORANGE
2. BRASS VALVE INDICATOR TO BE PROVIDED WITH ENGRAVED DIAGRAM OF VALVE LOCATION AND DESCRIPTION. (SEE EXAMPLE) INDICATOR SHALL BE FLUSH WITH PAD/PAVEMENT.
3. VALVE BOX LID SHALL BE A MINIMUM 24 LBS. WITH A MINIMUM 6" THROAT.
4. VALVE BOX SHALL COMPLY WITH FDOT STANDARDS IF APPLICABLE.

INDIAN RIVER COUNTY  
DEPARTMENT OF  
UTILITIES SERVICES



VALVE BOX PAD

DRAWING  
NO.

M-6

SEPTEMBER 2011