



NOTES

1. 3/4" GRAVEL BEDDING SHALL BE USED FOR EXCAVATION IN ROCK. SAND BEDDING SHALL BE USED FOR EXCAVATION IN SAND.
2. ALL MATERIALS ARE TO BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
3. MARKER BALLS TO BE TAPED TO 6"x4" 24" BELOW FINISHED GRADE.
4. PLUMBING CONTRACTOR WILL BE RESPONSIBLE FOR RISER PIPE WITH BEND FOR SERVICE CONNECTION AND FOR CUTTING 4" SEWER CLEANOUT TO FINISH GRADE PRIOR TO CONNECTION.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITIES SERVICES



MODIFIED RISER LATERAL
(DEEP SEWER)

DRAWING
NO.

S-2

JULY 2009