



NOTES

1. VALVE SPACING ON WATER MAINS SHALL NOT EXCEED 1000' MAXIMUM.
2. A MINIMUM COVER OF 36" IS REQUIRED ABOVE BELL OF D.I.P. AND P.V.C. PIPE.
3. CONTRACTOR IS RESPONSIBLE FOR THE INSTALLATION OF BLUE REFLECTIVE MARKERS (RAISED PENDANT MONUMENT) INDICATING A FIRE HYDRANT AND SHALL BE LOCATED IN THE CENTERLINE OF THE LANE CLOSEST TO THE HYDRANT.
4. DEAD END LINES, VALVES, AND HYDRANTS SHALL BE RESTRAINED.
5. ALL LINES SHALL BE A MINIMUM 10' OFFSET FROM BUILDINGS.
6. ALL MAINS LESS THAN 10' IN LENGTH AND LOCATED BETWEEN FITTINGS SHALL BE D.I.P.
7. REFLECTIVE MARKERS FOR:
 - FIRE HYDRANT - BLUE
 - WATER MAIN VALVE - WHITE
 - FORCE MAIN VALVE - GREEN
 - REUSE MAIN VALVE - PURPLE
8. THE APPROPRIATE REFLECTIVE MARKER IS REQUIRED FOR EACH VALVE.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITIES SERVICES



LOCATION DETAIL
(VALVE AND FIRE HYDRANT)

DRAWING
NO.

W-1

JULY 2009