



NOTES

1. ALL ABOVE GROUND PIPING SHALL BE PAINTED PANTONE PURPLE (522C).
2. PROVIDE A PLACARD WITH THE WORDS "RECLAIMED WATER IN USE."
3. ALL MATERIALS ARE TO BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
4. DISCHARGE INVERT TO BE ONE PIPE DIAMETER ABOVE METER TO MAINTAIN FULL PIPE.
5. A TELEMETRY AND MONITORING DEVICE IS REQUIRED AT DISCHARGE. TO BE INSTALLED IN STRICT ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS.

INDIAN RIVER COUNTY
 DEPARTMENT OF
 UTILITIES SERVICES



REUSE PIPE
 DISCHARGE DETAIL

JULY 2009

DRAWING
 NO.
 W-11
 A