



**NOTES**

1. ALL ABOVE GROUND PIPING SHALL BE PAINTED PANTONE PURPLE (522C).
2. PROVIDE A PLACARD WITH THE WORDS "RECLAIMED WATER IN USE."
3. ALL MATERIALS ARE TO BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
4. DISCHARGE INVERT TO BE ONE PIPE DIAMETER ABOVE METER TO MAINTAIN FULL PIPE.
5. A TELEMETRY AND MONITORING DEVISE IS REQUIRED AT DISCHARGE. TO BE INSTALLED IN STRICT ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS.

INDIAN RIVER COUNTY  
 DEPARTMENT OF  
 UTILITIES SERVICES



REUSE PIPE  
 DISCHARGE DETAIL

DRAWING  
 NO.  
 W-11  
 A

SEPTEMBER 2011