



## NOTES

1. TIE-IN VALVE SHALL BE OPERATED BY IRCBUS PERSONNEL ONLY AND IN THE PRESENCE OF THE ENGINEER OF RECORD.
2. ALL LINES TO BE FULL PIPE FLUSHED.
3. ALL MATERIALS TO BE PER IRCBUS APPROVED MANUFACTURERS' PRODUCT LIST.
4. A 2" TEMPORARY JUMPER TO BE USED UNLESS OTHERWISE DIRECTED BY IRCBUS.

INDIAN RIVER COUNTY  
 DEPARTMENT OF  
 UTILITIES SERVICES



TEMPORARY  
 JUMPER DETAIL

DRAWING  
 NO.

W-12

JULY 2009