



NOTES

1. METERS OVER 2" ϕ MUST BE APPROVED BY IRCDUS AND INSTALLED BY CONTRACTOR.
2. ALL METERS 2" ϕ AND SMALLER WILL BE SUPPLIED AND INSTALLED BY IRCDUS.
3. MINIMUM SIZE OF METER BOXES: 1" ϕ SERVICE (12" X 18"); 1-1/2" ϕ AND 2" ϕ SERVICE (17" X 28").